

Emission Test Certificate

Monday, 23rd March 2015

Supplier: LETObamboo (9 Glenvale Crescent, Mulgrave, VIC 3170)

Sample Description: Bamboo Ply – ‘Narrow Grain, Carbonised Colour’ 19mm (100% bamboo)

Date Tested: March 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Ecospecifier GreenTag	Bamboo Ply ‘Narrow Grain, Carbonised Colour’ 19mm
Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: <0.006 mg/m ² /hr
Formaldehyde Emission Rate limit <0.1mg/m ² /hr	Formaldehyde Emission Rate: <0.005 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV150303